



**THOMPSON  
& LITTON** EST.  
1956

ENGINEERS ARCHITECTS SURVEYORS

ADDENDUM NO. 003

**TO:** To Plan Holders

**RE:** Building 51 – Tenant Upgrade  
Roanoke Regional Airport Commission  
T&L Project No. 12813  
RRAC Bid No. 20-004

**DATE:** January 27, 2020



**BIDS RECEIVED DATE:** February 4, 2020, 2:00 PM

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated January 5, 2020 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of 1 page plus attachments.

**CLARIFICATIONS AND ANSWERS TO PRE-BID QUESTIONS:**

1. See attached questions and responses.

**CHANGES TO BIDDING REQUIREMENTS:**

1. None

**CHANGES TO SPECIFICATIONS:**

1. None

**CHANGES TO DRAWINGS:**

1. None

**Enclosures:** Pre-Bid Questions and Response – 1 Question



THOMPSON  
& LITTON

**REQUEST FOR INFORMATION**

RFI NO. 6

TO: Thompson & Litton, Inc.  
726 Auburn Avenue  
Radford, VA 24141  
FAX: (540) 633-1896  
Email: mturner@T-L.com

From: F&S Building Innovations Inc  
2944 Orange Ave NE  
Roanoke, Virginia 24012

Date: 1-24-2020

Please Respond By: \_\_\_\_\_

T&L Project No.: 12813  
Project Name: Building 51 – Tenant Upgrade

We request the following information/clarification:

The Asbestos Survey does not include a floor plan designating areas corresponding to what has been tested. Can one be provided in order to better ascertain the locations and quantities to be abated?

SIGNED: Bernardo Dacal-Teijeiro TITLE: Estimator

**T&L RESPONSE:**

There is no floor plan associated with the asbestos survey. The asbestos survey identifies flooring by color and description to indicate what tile is asbestos containing. The unit price square footages have incorporated these descriptions to determine a quantity.

BY: \_\_\_\_\_

DATE: \_\_\_\_\_