

Roanoke Regional Airport Commission IFB # 23-008 SECURITY FENCE UPGRADES

Addendum #2 June 23. 2023

The contents of this addendum represent solicitation questions and answers, notes, changes, additions or clarifications to the specifications. A conformed copy of the RFP reflecting all changes from Addendum #2 is also included as a separate attachment if needed.

- I. Questions and Answers
- Q1. Is a top rail desired or is tension wire acceptable?
- A1. Tension wire is desired
- Q1. The post specs in the "Technical Specifications" section has specs for fence "Above 8", but it does not specify for 8-foot-tall fence. Is the fence to be bid at those specs, or are they different for fence that is in face 8 foot tall?
- A1. The post needs to be slightly taller than 8' to accommodate the barbed wire angle. The actual fence needs to be 8' tall.
- Q2. In reference to the wild life deterrent fence can "new" fence be used for that instead of cutting the old fence in half. Also, if this is an available option, can 4-foot-tall be used instead of 3 foot.
- A2. We don't have an issue with "new" fence being used as long as it is the same gauge as the existing. We were trying to use previous fence as a cost-saving method. 4 foot would be a suitable option as well.

- Q3. Is the entire fence perimeter to be grounded, or just where there is power lines at?
- A3. The entire fence perimeter needs to be grounded.
- Q4. Is there a blueprint or sketch for the project that you can send out?
- A4. We do not have a blueprint for this project as we are just replacing existing fence.
- Q5. Do contractors need to be certified by VDOT to perform this work as per the question on the bid form?
- A5. No, it is not required

II. Aerial Pictures

Please see photos below where the fence being replace is highlighted in red.


III. Pre-bid Sign-in Sheet

Please see Attachment A for the sign-in sheet.

IV. Swell Supplemental Drawing

Please see Attachment B for the swell supplemental drawing

Phase 1



Phase 2



End of Addendum #2

Attachment A



DATE: 6/13/2023


MEETING:

IFB # 23-008 Security Fence Upgrades

ATTENDANCE

COMPANY	EMAIL ADDRESS
Powers Fence Company, Truc.	guardra: 1 voamoke @ Verizou. Net
Frye Ferre 3 Curbscoping LLC	Fryefence and curba yahoo. wan
Fence + Field LLC	Fence & Field @gmail.com
long Fence	dtuckwiller@longfeuce.com
RRFC	Tray. Phil pott @ fly rou. com
12RAC	Jay. hill @ Ayroa.com
×	
ik .	
	Force + Field LLC Long Fence RRACE

Attachment B



WILDLIFE EXCLUSION FENCE DITCH CROSSING

SOME ITEMS OMITTED FOR CLARITY NOT TO SCALE

NOTE: REFER TO F-164 WILDLIFE EXCLUSION FENCE FOR SPECIFICATIONS.